



# Laboratory Report

Environmental Health Division

**WSLH Sample: 622880001**

Report To:  
KEVIN BREIT  
225 MAIN ST  
MOSINEE, WI 54455

Invoice To:  
KEVIN BREIT  
225 MAIN ST  
MOSINEE, WI 54455  
Customer ID: 73724805

System Name: MOSINEE EAST SYSTEM  
City: MOSINEE  
Collection Date/Time: 06/02/2022 09:45  
Collected By: P SEEFELDT  
County: MARATHON  
Source Code: E - Entry Point  
Collection Address: 500 MAPLE RIDGE RD  
Location of Sample: SAMPLE TAP

Monitor Point ID: EP1  
PWS ID#: 73724805  
WI Unique Well#: BG305  
**Entry Point ID: 1**  
Date Received: 6/3/2022  
Date Reported: 6/16/2022  
Sample Type: I-Investigation

## PFAS in Water

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 06/08/22 10:00		Analysis Date: 06/10/22 20:07			
PFBA (375-22-4)	WSLH PFAS in Water	2.87	ng/L	0.332	0.959
PFPeA (2706-90-3)	WSLH PFAS in Water	0.543F	ng/L	0.144	0.959
PFBS (375-73-5)	WSLH PFAS in Water	2.09	ng/L	0.221	0.959
4:2 FTSA (757124-72-4)	WSLH PFAS in Water	<0.182	ng/L	0.182	0.959
PFHxA (307-24-4)	WSLH PFAS in Water	0.739F	ng/L	0.196	0.959
PFPeS (2706-91-4)	WSLH PFAS in Water	<0.130	ng/L	0.130	0.959
HFPO-DA (13252-13-6)	WSLH PFAS in Water	<0.184	ng/L	0.184	0.959
PFHpA (375-85-9)	WSLH PFAS in Water	1.11	ng/L	0.144	0.959
PFHxS (355-46-4)	WSLH PFAS in Water	0.892F	ng/L	0.136	0.959
DONA (919005-14-4)	WSLH PFAS in Water	<0.123	ng/L	0.123	0.959
6:2 FTSA (27619-97-2)	WSLH PFAS in Water	<0.261	ng/L	0.261	0.959
PFOA (335-67-1)	WSLH PFAS in Water	8.49	ng/L	0.104	0.959
PFHpS (375-92-8)	WSLH PFAS in Water	0.292F	ng/L	0.182	0.959
PFOS (1763-23-1)	WSLH PFAS in Water	28.0	ng/L	0.137	0.959
PFNA (375-95-1)	WSLH PFAS in Water	0.327F	ng/L	0.142	0.959
9CI-PF3ONS (756426-58-1)	WSLH PFAS in Water	<0.174	ng/L	0.174	0.959
8:2 FTSA (39108-34-4)	WSLH PFAS in Water	<0.251	ng/L	0.251	0.959

Environmental Health Division

**WSLH Sample: 622880001**

## PFAS in Water

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 06/08/22 10:00		Analysis Date: 06/10/22 20:07			
PFDA (335-76-2)	WSLH PFAS in Water	<0.156	ng/L	0.156	0.959
PFNS (68259-12-1)	WSLH PFAS in Water	<0.174	ng/L	0.174	0.959
N-MeFOSAA (2355-31-9)	WSLH PFAS in Water	<0.210	ng/L	0.210	0.959
N-EtFOSAA (2991-50-6)	WSLH PFAS in Water	0.386F	ng/L	0.203	0.959
FOSA (754-91-6)	WSLH PFAS in Water	0.755F	ng/L	0.149	0.959
PFOA (2058-94-8)	WSLH PFAS in Water	<0.213	ng/L	0.213	0.959
PFDS (335-77-3)	WSLH PFAS in Water	<0.246	ng/L	0.246	0.959
11CI-PF3OUdS (763051-92-9)	WSLH PFAS in Water	<0.143	ng/L	0.143	0.959
PFDoA (307-55-1)	WSLH PFAS in Water	<0.260	ng/L	0.260	0.959
PFDoS (79780-39-5)	WSLH PFAS in Water	<0.237	ng/L	0.237	0.959
PFTTrDA (72629-94-8)	WSLH PFAS in Water	<0.185	ng/L	0.185	0.959
N-MeFOFA (31506-32-8)	WSLH PFAS in Water	<0.959	ng/L	0.959	1.92
N-MeFOSE (24448-09-7)	WSLH PFAS in Water	<0.269	ng/L	0.269	0.959
N-EtFOFA (4151-50-2)	WSLH PFAS in Water	<0.665	ng/L	0.665	1.92
N-EtFOSE (1691-99-2)	WSLH PFAS in Water	<0.203	ng/L	0.203	0.959
PFTeDA (376-06-7)	WSLH PFAS in Water	<0.168	ng/L	0.168	0.959