Wisconsin State Laboratory of Hygiene 2601 Agriculture Drive, PO Box 7996 Madison, WI 53707-7996 (800)442-4618 - FAX (608)224-6213 http://www.slh.wisc.edu

Laboratory Report

Environmental Health Division

WSLH Sample: 622877001

Report To:

KEVIN BREIT 225 MAIN ST

MOSINEE, WI 54455

Invoice To:

KEVIN BREIT 225 MAIN ST

MOSINEE, WI 54455

Customer ID:

73724805

System Name: MOSINEE EAST SYSTEM

City: MOSINEE

Collection Date/Time: 06/02/2022 09:00

Collected By: P SEEFLEDT

County: MARATHON

Source Code: E - Entry Point

Collection Address: 500 MAPLE RIDGE RD

Location of Sample:

SAMPLE TAP

Monitor Point ID: EP2

PWS ID#: 73724805

WI Unique Well#: BG306

Entry Point ID: 2

Date Received: 6/3/2022

Date Reported:

Sample Type:

6/16/2022 I-Investigation

PFAS in Water

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 06/08/22 10:00	Analysis Date: 06/10/22 19:3	6			
PFBA (375-22-4)	WSLH PFAS in Water	0.408F	ng/L	0.326	0.942
PFPeA (2706-90-3)	WSLH PFAS in Water	<0.141	ng/L	0.141	0.942
PFBS (375-73-5)	WSLH PFAS in Water	1.06	ng/L	0.218	0.942
4:2 FTSA (757124-72-4)	WSLH PFAS in Water	<0.179	ng/L	0.179	0.942
PFHxA (307-24-4)	WSLH PFAS in Water	<0.192	ng/L	0.192	0.942
PFPeS (2706-91-4)	WSLH PFAS in Water	0.250F	ng/L	0.128	0.942
HFPO-DA (13252-13-6)	WSLH PFAS in Water	<0.181	ng/L	0.181	0.942
PFHpA (375-85-9)	WSLH PFAS in Water	<0.141	ng/L	0.141	0.942
PFHxS (355-46-4)	WSLH PFAS in Water	2.04	ng/L	0.134	0.942
DONA (919005-14-4)	WSLH PFAS in Water	<0.121	ng/L	0.121	0.942
6:2 FTSA (27619-97-2)	WSLH PFAS in Water	<0.256	ng/L	0.256	0.942
PFOA (335-67-1)	WSLH PFAS in Water	0.297F	ng/L	0.102	0.942
PFHpS (375-92-8)	WSLH PFAS in Water	<0.179	ng/L	0.179	0.942
PFOS (1763-23-1)	WSLH PFAS in Water	2.73	ng/L	0.135	0.942
PFNA (375-95-1)	WSLH PFAS in Water	<0.139	ng/L	0.139	0.942
9CI-PF3ONS (756426-58-1)	WSLH PFAS in Water	<0.172	ng/L	0.172	0.942
8:2 FTSA (39108-34-4)	WSLH PFAS in Water	<0.247	ng/L	0.247	0.942

Wisconsin State Laboratory of Hygiene 2601 Agriculture Drive, PO Box 7996 Madison, WI 53707-7996 (800)442-4618 - FAX (608)224-6213 http://www.slh.wisc.edu

Laboratory Report

Environmental Health Division

WSLH Sample: 622877001

PFAS in Water

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 06/08/22 10:00	Analysis Date: 06/10/22 19:3	6			
PFDA (335-76-2)	WSLH PFAS in Water	<0.154	ng/L	0.154	0.942
PFNS (68259-12-1)	WSLH PFAS in Water	<0.172	ng/L	0.172	0.942
N-MeFOSAA (2355-31-9)	WSLH PFAS in Water	<0.206	ng/L	0.206	0.942
N-EtFOSAA (2991-50-6)	WSLH PFAS in Water	<0.200	ng/L	0.200	0.942
FOSA (754-91-6)	WSLH PFAS in Water	<0.146	ng/L	0.146	0.942
PFUnA (2058-94-8)	WSLH PFAS in Water	<0.209	ng/L	0.209	0.942
PFDS (335-77-3)	WSLH PFAS in Water	<0.242	ng/L	0.242	0.942
11CI-PF3OUdS (763051-92-9)	WSLH PFAS in Water	<0.140	ng/L	0.140	0.942
PFDoA (307-55-1)	WSLH PFAS in Water	<0.255	ng/L	0.255	0.942
PFDoS (79780-39-5)	WSLH PFAS in Water	<0.233	ng/L	0.233	0.942
PFTrDA (72629-94-8)	WSLH PFAS in Water	<0.182	ng/L	0.182	0.942
N-MeFOSA (31506-32-8)	WSLH PFAS in Water	<0.942	ng/L	0.942	1.88
N-MeFOSE (24448-09-7)	WSLH PFAS in Water	<0.265	ng/L	0.265	0.942
N-EtFOSA (4151-50-2)	WSLH PFAS in Water	<0.654	ng/L	0.654	1.88
N-EtFOSE (1691-99-2)	WSLH PFAS in Water	<0.200	ng/L	0.200	0.942
PFTeDA (376-06-7)	WSLH PFAS in Water	<0.165	ng/L	0.165	0.942