



Laboratory Report

Environmental Health Division

WSLH Sample: 617856001

Report To:
KEVIN BREIT
225 MAIN ST
MOSINEE, WI 54455

Invoice To:
KEVIN BREIT
225 MAIN ST
MOSINEE, WI 54455
Customer ID: 73724805

System Name: MOSINEE EAST SYSTEM
City: MOSINEE
Collection Date/Time: 05/04/2022 12:50
Collected By: P SEEFELDT
County: MARATHON
Source Code: E - Entry Point
Collection Address: 500 MAPLE RIDGE RD
Location of Sample: SAMPLE TAP

Monitor Point ID: EP1
PWS ID#: 73724805
WI Unique Well#: BG305
Entry Point ID: 1
Date Received: 5/5/2022
Date Reported: 5/24/2022
Sample Type: I-Investigation

PFAS in DW

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 05/06/22 11:00		Analysis Date: 05/10/22 00:25			
PFBS (375-73-5)	EPA Method 537.1	1.54	ng/L	0.950	0.950
The Relative Percent Difference for the MS and MSD does not meet the QC limit.					
PFHxA (307-24-4)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
HFPO-DA (13252-13-6)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
PFHpA (375-85-9)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
PFHxS (355-46-4)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
DONA (919005-14-4)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
PFNA (375-95-1)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
PFOS (1763-23-1)	EPA Method 537.1	29.4	ng/L	0.950	0.950
The Relative Percent Difference for the MS and MSD does not meet the QC limit.					
9CI-PF3ONS (756426-58-1)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
PFDA (335-76-2)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
N-MeFOSAA (2355-31-9)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
N-EtFOSAA (2991-50-6)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
PFUnA (2058-94-8)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
PFOA (335-67-1)	EPA Method 537.1	9.34	ng/L	0.950	0.950
11CI-PF3OUdS (763051-92-9)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
PFDoA (307-55-1)	EPA Method 537.1	<0.950	ng/L	0.950	0.950



Laboratory Report

Environmental Health Division

WSLH Sample: 617856001

PFAS in DW

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 05/06/22 11:00		Analysis Date: 05/10/22 00:25			
PFTTrDA (72629-94-8)	EPA Method 537.1	<0.950	ng/L	0.950	0.950
PFTeDA (376-06-7)	EPA Method 537.1	<0.950	ng/L	0.950	0.950